

Testing. Advising. Assuring.

EWFA CERTIFICATE OF ASSESSMENT	CERTIFICATE No : SFC FAS180478.1	Page 1 of 1
---------------------------------------	---	--------------------

Report Sponsor	Certificate Issue Date	Product Name
Tekt Tile Australia, 24 Stennett Road, Ingleburn, NSW 2565, Australia	20/11/2018	Interlocking Flooring Tile "DT8/0.7/WL/PU" composite

Introduction

The element of construction described below was assessed by this laboratory on behalf of the report sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report(s) or Regulatory Information Reports for more information.

Referenced Report	Report Date	Validity Date	Test Standard
FAS180478.1	20/11/2018	30/11/2023	AS ISO 9239.1-2003

Summary of Assessed Construction					
Generic Description	Product Reference	Thickness	Weight per unit area, density	Results	
Interlocking Flooring Tile	"DT8/0.7/WL/PU"	7.96mm	11.17 kg/m ²	Average Maximum flame front distance: 21cm Average critical radiant flux: 9.3kW/m² Average smoke development: 235.40% min Average maximum light attenuation: 49.38%	
Individual components used to manufacture composite					
Vinyl Insert	"LVT PU"	2mm	0.0004kg/m ²		
• PU Coating	"DT WL"	0.7mm	0.07kg/m ²		
• Wear Layer	"DT 7D"	0.2mm	0.005kg/m ²		
• Print Layer	"Design Tile Base"	5mm	6kg/m ²		
• PVC Backing					
Adhesive	"7005.1"	N/A	100 g/m ²		
PVC Substrate	"Moulded Design Tile Tray"	5.5mm	1.45g/cm ³		
Substrate	"NT D4 604"	8mm	1900±200kg/m ³		

Notes

This Certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance.

Reference should be made to the relevant test report or regulatory information report to determine the applicability of the test result to a proposed installation.

The results of these fire tests may be used to assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all conditions.

TESTING AUTHORITY	Exova Warringtonfire Aus Pty Ltd	
Address	Unit 2,409-411 Hammond Road, Dandenong South, Australia	
Phone	+61 (0)3 9767 1000	
ABN	81 050 241 524	
Email / Home Page	www.exova.com	
Authorisation	Prepared By: M.Aki	Reviewed By: T.Bhat